

Fax

TO:
~~BOB SCHAEFER~~
ED MALTER



To: Kevin Hess, MDNR Regional Office

Fax: 891-4399

Phone: 891-4300

Date: June 11, 2002 (1:24pm)

Re: *Sanitary Sewer Overflow-Brewery Spring/Jordan Creek*

From: Randy Lyman, Pretreatment Coordinator

Pages: 2 , including this cover sheet.

Comments: As discussed by phone spill report on 6/10/2001.

From the desk of:

J. Randall Lyman

Pretreatment Coordinator

City of Springfield, Mo.

1216 W. Nichols St.

Springfield, Mo. 65807

phone 417-864-1487

fax 417-864-1918

randy_lyman@ci.springfield.mo.us

TAMMY,
FYI
Randy.

C:\MyFiles\800wcollege2.wpd

800 W. COLLEGE



SANITARY SEWER OVERFLOW REPORT TO DEPARTMENT OF NATURAL RESOURCES

Received Notice of Overflow: Time 2:15 P.M. Date 6 / 7 / 2002

Location of Overflow: 800 W. College St. (Approximate Address)

Received by: Name Tammy Ikerd Telephone No. 864-1924

Assigned To: Crew Homer Trantham & Mike Shaw Time 2:15 P.M. Date 6 / 7 / 2002

Overflow Point--M.H. # 106, NE 1/4, S 23 T 29 R 22

Overflow Basin-- Jordan Creek

Estimated Time Overflow Started: Time 1 : 30 P.M., Date 6 / 7 / 2002

Estimated Flow at Time of Response < 2 G.P.M.

Estimated/Actual Time Overflow Ceased: Time 2 : 30 P.M., Date 6 / 7 / 2002

Cause of Overflow: I/I ☐ Roots ☐ Grease ☒ Debris ☐ Vandalism ☐
Other ☐ (Describe): Bread Flour Dough in Aged Defective Sewer Lines

Action Taken to Eliminate or Lessen Overflow: Unclogged with high pressure sewer flusher, scheduled 810 feet of Insituform rehab. at \$40 per foot and manhole rehab. around Jan. 1, 2003.

Overflow Reported To: MDNR Regional Office, 4 : 15 P.M., Date 6 / 10 / 2002
_____, _____, _____ A.M./P.M., Date / /
_____, _____, _____ A.M./P.M., Date / /

Overflow Estimated Amount Total < 50 Gallons

Remedial Actions:

Pumpback to sewer: ☐ Debris cleanup: ☐ Limed: ☐ Other: ☒ Flusher washed off street

Comments or other information: Washed greasy spot and particles of grease and dough off street to ditch. Water soaked into ground and amount of grease and solids was determined to be unrecoverable amount. Virtually unnoticeable on 6/10/2002 at 3:30P.M. Brewery Spring had turned white over weekend. Began clearing up on 6/10/2002. Clear on 6/11/2002. Now, in retrospect, we suspect similar incident on 2/14/2002. No sewer overflow occurred. Spring turned white, vandalism discovered in same line ~400 ft north. Dye injected in sewer, none detected over President's Day weekend. Rain event in mid-week following flushed out stream and spring. Connection of sewer stoppage and spring condition was highly suspicious. No dye was ever detected, however.

Signature: J. Russell Ayman Date: 6 / 11 / 2002 MDNR college wpt

800 W. College

Brewery Spring

Sewer Stoppage

Butternut Bakery

MOPACRR

WATER

800 W. Cottage

BNSF
142922 N18
BNSF

Lyman, Randy

From: Chandler, Karen
Sent: Friday, February 15, 2002 4:16 PM
To: Pabst, Gene; Corson, Bob
Cc: Lyman, Randy
Subject: Spring at Fort & Jordan

February 15, 2002; 3:50 p.m. I checked the spring at Fort and Jordan. There was no green dye coming out of the spring at this time.